



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20216468	Date:	June 21, 2022
Project Title:	BLUE SKY FERTILITY	Applicant:	
Location:			
455 NW MURRAY RD, LEES SUMMIT, MO 64081		Aegis Fire Protection LLC	
Type of Work:		13415 W. 98th Street	
Occupancy Group:	B	Lenexa, KS 66215	
Description:	TENANT FINISH FOR FERTILITY CLINIC	Primary:	(913) 839-0183
Construction Type:	Type VB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required- Call (816) 969-1300 to schedule an alarm test. Schedule the test outside of the neighboring business's regular hours.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.