

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213720
Address: 4713 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Tuesday, June 21, 2022

Corrective Action Required:

1	Misc	-Protect 3/4" csst gas line per manufacturer: Cannot secure csst gas line within stud space. Csst gas line must be able to be displaced min 3"; protect min 5" beyond wall plates **Please read the manufacturer installation manual available from its website
---	------	---

**OK TO INSULATE

Comments: