

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201467

Address: 1425 SW WARD RD, LEES SUMMIT, MO 640811515 SW WARD RD, LEES SUMMIT, MO 640811000 SW WINTHROP DR, LEES SUMMIT, MO 64081930 SW SCHERER RD, LEES SUMMIT, MO 640821401 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Nick Lightner	Partial	Tuesday, June 21, 2022

Informational:

1 Misc 6-9-22 AN. Both water mains have been chlorinated on 6-8-22

6-13-22 AN first round of water samples were done 4 samples

Corrective Action Required:

2 Misc 6-15-22--- 6-21-22 AN first round of samples fail both mains . Will have to flush and chlorinate the both mains again

Comments: