

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215222
Address: 2039 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Tuesday, June 21, 2022

Corrective Action Required:

1	Misc	-address over notched joist above garage for dwv Provide documents for fix-NO DOCUMENTS FOUND -install all windows see basement-NOT DONE
---	------	---

Okay to insulate

Comments: