

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215298
Address: 3208 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, June 21, 2022

Corrective Action Required:

1 Misc

- pfh at single car garage per plans
- seal top plate penetrations garage entry
- seal bottom plate penetrations garage entry
- top plate penetrations master closet
- fire block dead space to ceiling space master bath
- seal bottom plate penetrations kitchen
- complete oven hood vent
- cspf nailing to code
- seal top and bottom plate penetrations through out
- complete bath vent bath 2
- in correct hanger for truss above master
- solid blocking under kitchen island per plans
- address over notched joisted in basement near furnace also in middle 1/3
- address over notched joist for furnace line set

Comments: