## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRCOM20216411Address:710 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Water Line - Coliform Test 1		Eric Sharp	Partial	Tuesday, June 21, 2022
Informational:				
1	Misc	Richard's crew chlorinated fire line from construction tap to end of line. Will let sit chlorinated over weekend. 6/16/22 ES		
		Dechlorinated line with dechlorination pellets and flushed after dechlorinating. 6/20/22 ES		
		Took 2 samples from fire line. 1 from before backflow on public side and one from end of line. 6/21/22 ES		

Comments: