

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20214936

Address: 1745 SE HAMBLER RD, LEES SUMMIT, MO 640821800 SE RANSON RD, LEES SUMMIT, MO
640821001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	Tom Taylor	Passed	Monday, June 20, 2022

Informational:

1 Misc On Monday, 6-20-2022. Site Rite performed and passed Mandrel test on the 15" sewer for this project.

Comments: