

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216118
Address: 2024 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, June 22, 2022

Informational:

1	Miscellaneous Correction	-Portal frame pass This inspection to be done at all rough.
---	--------------------------	--

Not ready for rough inspection

Corrective Action Required:

2	Miscellaneous Correction	- Nail off all LIB's through out - Complete vent in garage - Provide hangers on doubles at cat walk - Nail cspf and add straps in master bedroom - Strap top plate master closet - Open front porch covering for inspection - Add stud under LVL bedroom 4 exterior wall - Strap DWV 2" and under second floor - Provide window bedroom 2 - Fire block penetration bedroom 4 top plate
---	--------------------------	---

Comments: