

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213382
Address: 3208 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, June 22, 2022

Corrective Action Required:

1	Misc	-final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -check water meter at time of final grade and sod -obtain lawn irrigation permit -address pending sidewalk and water service inspection -open junction boxes foyer and office -garage entry door must be self closing and latching
---	------	--

Comments: