

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213681
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Failed	Wednesday, June 22, 2022

Informational:
1 Misc -3rd party inspector to verify and document nailing pattern at exterior sheathing

Corrective Action Required:
2 THIRD FLOOR Area "A"
-Support rc channel throughout-max length unsupported 4"

Comments: