

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214475
Address: 205 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Eric Sharp	Passed	Wednesday, June 22, 2022

Informational:

1 Misc

Driveway was framed up with aggregate in and compacted. Had one small section of curbing that needed patched as well. 6/14/22 ES

Driveway meets LS and ADA specs. 6/22/22 ES

Comments: