

Builders First Source  
131 West Industrial  
Valley Center, Kansas 67147  
Office: 316.755.3114

June 14, 2022

Summit Homes Lot 128 MN

Re: D6 roof truss connections

This letter is to verify changes made to the roof truss layout on 6/14/2022. The modifications were made to both D6 connections, one using a new TJC57 hanger on only one face and the other D6 now nailed into the wall behind it as a ledger/nailer.

If any questions please contact me via email or phone below.

Scott Clevenger  
Component Sales Manager – KC  
Mobile: 316.252.7862  
scott.clevenger@bldr.com

