

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216110
Address: 3528 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Patrick Schonfeldt	Partial	Wednesday, June 22, 2022

Corrective Action Required:

1	Misc	6/13/22 - LIGHT TEST PARTIAL HOOD INSPECTION 6/14/22 - 1ST LAYER WRAP 6/15/22 - 2ND LAYER WRAP 6/16/22 - LIGHT TEST AT EXTENSIONS 6/17/22 - LIGHT TEST AT HOOD TO DUCT, 1ST LAYER WRAP ON EXTENSIONS 6/22/22 - 2ND LAYER WRAP, FRESH AIR DUCTS
---	------	---

Comments: