

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216323
Address: 3209 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, June 22, 2022

Corrective Action Required:

1	Misc	-anchor bolts at pfh to be tight -over notched stud at N garage wall -Address hole in sheathing N garage wall -Address roof sheathing not installed to manufacture specifications -protect NM within 6' of attic access -stud packs at gt bearing points in dining room -Connect ufer ground to middle grounded bus bar -uncover ufer connection
---	------	---

Comments: