



PROJECT NAME John Knox Village – Salon – TI Package
CLIENT NAME John Knox Village
PROJECT NO. 22009
Date: June 22, 2022

Drawings:

A101

10A – FLOOR PLAN

1. Revised exhaust system to portable direct source capture units at manicure and pedicure stations.
2. Added wall build-out enclosures to conceal ductwork to ceiling for portable exhaust units.
3. Added soap dispensers and paper towel holders.
4. Relocated fire extinguisher to lobby area.

5A – REFLECTED CEILING PLAN

1. Revised exhaust fans, added vertical ducts for portable direct source-capture units (RE: Mechanical sheets)
2. Revised molding and ceiling grid to accommodate wall build-out enclosures for portable exhaust unit ducts.

FF&E SCHEDULE

1. Corrected finish notes for furniture items #12, #13, #16
2. Updated faucet fixture specification (#37)
3. Updated soap dispenser fixture (#38)
4. Added portable direct source capture exhaust units (#46) and paper towel holders (#47)

A201

C11 – ENLARGED FLOOR PLAN

1. Revised exhaust system to portable direct source capture units at manicure and pedicure stations.
2. Added wall build-out enclosures to conceal ductwork to ceiling for portable exhaust units.
3. Added soap dispensers and paper towel holders.

F6 – ENLARGED FLOOR PLAN

1. Revised exhaust system to portable direct source capture units at manicure and pedicure stations.
2. Added wall build-out enclosures to conceal ductwork to ceiling for portable exhaust units.

F3 – ENLARGED FLOOR PLAN

1. Revised exhaust system to portable direct source capture units at manicure and pedicure stations.
2. Added wall build-out enclosures to conceal ductwork to ceiling for portable exhaust units.

A11 – ENLARGED FLOOR PLAN

1. Added soap dispensers and paper towel holders.



A9 – ENLARGED FLOOR PLAN

1. Added soap dispensers and paper towel holders.

A6 – ENLARGED FLOOR PLAN

1. Added soap dispensers and paper towel holders.

A301

DOOR SCHEDULE

1. Added note for non-lockable hardware on Massage Room door.

A8 – WEST SECTION

1. Added wall build-out enclosures to conceal ductwork to ceiling for portable exhaust units.
2. Added soap dispenser and paper towel holder.

A401

J12 – ELEVATION

1. Added wall build-out enclosures to conceal ductwork to ceiling for portable exhaust units.

H9 – ELEVATION

1. Added wall build-out enclosures to conceal ductwork to ceiling for portable exhaust units.
2. Added dimensions of countertop height.

H5 – ELEVATION

1. Added dimensions of countertop height.

F12 – ELEVATION

1. Added dimensions of countertop height.

F5 – ELEVATION

1. Added dimensions of countertop height.
2. Added soap dispenser and paper towel holder.

E12 – ELEVATION

1. Added dimensions of countertop height.
2. Added soap dispenser and paper towel holder.

E9 – ELEVATION

1. Added dimensions of countertop height.
2. Added soap dispenser and paper towel holder.

E5 – ELEVATION

1. Added dimensions of countertop height.
2. Added soap dispenser and paper towel holder.

E4 – ELEVATION

1. Added dimensions of countertop height.
2. Added soap dispenser and paper towel holder.

A402

A8 – DETAIL

1. Added note to refer to structural sheets.

A5 – DETAIL

1. Correction of blocking size from 1x8 to 2x8.



A501

D4 – FLOOR FINISH PLAN

1. Moved side table and finish tags.

MATERIAL SCHEDULE

1. Changed P4 paint to epoxy based paint.
2. Corrected Plastic Laminate finish information.

M201

1 – MECHANICAL FLOOR PLAN

1. Added source capture system for nail stations and adjusted ductwork accordingly. Keynote added for source capture system.
2. Revised keynotes for adjusted ducting and ventilation.

2 – EXHAUST FAN SCHEDULE

1. Revised EF-2 and EF-3 per ventilation calculations

3 – VENTILATION CALCULATIONS

1. Added ventilation calculation schedule to show compliance. Airflow and ventilation rates adjusted accordingly on plan.

E201

1 – ELECTRICAL POWER PLAN

1. Added (2) receptacles for power to source capture exhaust units in manicure/pedicure area.

E402

1 – ELECTRICAL SCHEDULES

1. Added (1) circuit for power to source capture exhaust units in panel 'LA'.

P101

1 – PLUMBING NOTES, SYMBOLS & ABBREVIATIONS

1. Revised pipe material types to be cast iron.

Specifications:

09 9000 – Painting and Coating (G501)

D. Paint Systems, 3.

- Revised – All material shall be of the standard commercial grade of the types designated.

E. Application / Installation, B. Interior Work, 1.

- Added – Paint shall be washable and mold-resistant in massage rooms.

End of Addendum