



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20100207
Address: 3340 NE RALPH POWELL RD, Unit:A, LEES SUMMIT, MO
64064
Inspected On: Thursday, February 17, 2011
Inspected By: Khanh NguyenKhanh NguyenJoe DirJoe Dir
Expiration Date: 3/17/2011 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Thursday, February 17, 2011

Corrective Action Required:

1 MISC PROVIDE A NO-SMOKING SIGN AT ENTRANCE

Corrective Action Required:

2 MISC FOR A/C UNIT:
-INSTALL ONE GFCI RECEPTACLE (WITH WEATHER PROOF
COVER PER NEC 406.8) WITHIN 25 FT OF A/C UNIT
-SEAL A/C LINES PENETRATION OF EXTERIOR WALL

Alarm Test	Joe Dir	Passed	Thursday, February 17, 2011
-------------------	---------	--------	--------------------------------

Occupancy Inspection - Fire	Joe Dir	Passed	Thursday, February 17, 2011
--	---------	--------	--------------------------------

Comments: