

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215300
Address: 500 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	John Jackson	Passed	Thursday, June 23, 2022

Informational:
1 Misc 6-3-22 AN Bair did fly ash proof roll (passed) then Geo grid with rock on that. Ask Steve if they need a second proof roll.

Informational:
2 Misc 06/23/22 Thursday (Bair Construction)
Proof passed on the 06/21/22 Tuesday.

Comments: