CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216411

Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Water Line - Coliform Test 1 Eric Sharp Passed Thursday, June 23,

2022

Informational:

1 Misc Richard's crew chlorinated fire line from construction tap to end of line. Will

let sit chlorinated over weekend. 6/16/22 ES

Dechlorinated line with dechlorination pellets and flushed after

dechlorinating. 6/20/22 ES

Took 2 samples from fire line. 1 from before backflow on public side and one

from end of line. 6/21/22 ES

Water samples #1 passed. 6/22/22 ES

Comments: