

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220198  
Address: 2106 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Thursday, June 23, 2022

Corrective Action Required:

1 Misc

-Master bathroom shower trap weir is above the vent connection Shawn Hoffman 06/23/2022 9:05 AM [ NOT COMPLETE ]

**\*\*OK TO INSULATE**

**Comments:**