

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204198
Address: 125 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, June 23, 2022

Corrective Action Required:

1	Miscellaneous Correction	- UNCOVER WATER METER AND BRING ACCESS TO GRADE LEVEL WITH METER 14 -18' FROM TOP.
---	--------------------------	--

Comments: