

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212552
Address: 3109 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, June 17, 2022

Corrective Action Required:

1	Misc	-address pending driveway and sidewalk inspections - sod -check water meter at time of final grade and sod -GFCI protection for 1floor bath -handrail to basement -lock out for oven breaker -GFCI protection required for all out door outlets.
---	------	--

Comments: