

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213815
Address: 1905 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, June 23, 2022

Corrective Action Required:

1	Misc	-covered deck install hangers,lags to plans and code, (PROVIDE MANUFACTURER LISTING THAT SHOWS STRUCTURAL TRUSS SCREWS CAN BE USED FOR LEDGER LAGS)
		OK TO INSULATE

Comments: