

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20213588

Address: 3703 SW WALSH DR, LEES SUMMIT, MO 640823705 SW WALSH DR, LEES SUMMIT, MO 640823707  
SW WALSH DR, LEES SUMMIT, MO 640823701 SW WALSH DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Thursday, June 23, 2022

Corrective Action Required:

1	Misc	UNIT 3701: OK TO INSULATE AND ROCK
		UNIT 3703: OK TO INSULATE AND ROCK
		UNIT 3705: -support all DWV every 48" oc -overnotched floor joist for DWV garage -address broken truss master bed  *OK TO INSULATE*
		UNIT 3707: OK TO INSULATE AND ROCK

**Comments:**