

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220646
Address: 805 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Khanh Nguyen	Failed	Thursday, June 23, 2022

Corrective Action Required:

1	Misc	**PROVIDE APPROVED SET OF PLAN ON SITE
		-PROVIDE LIGHT TEST WITH MIN 100 W LIGHT BULB

Comments: