

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215839
Address: 1924 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, June 23, 2022

Corrective Action Required:

1	Misc	-provide CS-PF portal bracing at great room exterior wall per plans (plans call out for dbl 2x12 header corner to corner, nail all exterior sheathing per design) -have engineer address B1 gable truss that has had webs cut and bottom chord removed (REPAIR PER ENGINEER LETTER) -fireblock between top plate and foundation wall basement bedroom -fireblock vertical every 10' behind studs at basement bedroom -install all windows
---	------	---

Comments: