

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213630  
Address: 433 NW KAYLEA CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Robb Popp	Failed	Friday, June 24, 2022

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	6/24/22
---	----------------------------	---------

EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. (BY RE INSPECTION ON 6/29/22)

-PROVIDE AND MAINTAIN EROSION CONTROL AT PERIMETER UNTIL SOD IS IN PLACE.

-CLEAN SILT AND DEBRIS FROM STREET, SIDEWALK AND STORM INLET IMMEDIATELY

**Comments:**