

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216314  
Address: 4409 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                 | Inspector:   | Outcome: | Date:                 |
|---|--------------|----------|-----------------------|
| <b>Gas Service Inspection - Residential</b> | Mark Harding | Failed   | Friday, June 24, 2022 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | NO PSI'<br>Bind gas line or provide listing on CSST used |
|---|------|--|

**Comments:**