

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204399  
Address: 617 SE 6TH ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	John Jackson	Partial	Friday, June 24, 2022

Informational:  
1 Misc 06/24/22 Friday  
Contractor is required to install one 15" storm pipe or two 12" pipe to continue Storm runoff throughout drain ditch. Contractor will call in another inspection when they ready for pre-inspection.

**Comments:**