

DEVELOPMENT SERVICES

Residential Plan Review

June 24, 2022

JFE CONSTRUCTION INC 1314 SW MARKET ST LEES SUMMIT, MO 64081 (816) 470-0074

Permit No: PRRES20222877

Plan Name:

Project Address: 2105 NW OBRIEN RD, LEES SUMMIT, MO 64081

Parcel Number: 262453

Location:

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE - UNFINISHED BASEMENT - COVERED DECK

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Kim Brennan Rejected

1. Minimum Building Opening Elevation (MBOE) and location on structure must be provided on the plot plan.

No MBOE's are shown on the MDP for this lot

Residential Plan Review Reviewed By: Kim Brennan Rejected

1. Identify emergency escape openings from bedrooms and basement(s). (IRC Section R310 as amended per Ordinance)

Not shown out of bedroom #2.

Planning Review RES Reviewed By: Shannon McGuire Approved

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:	
Residential, Decks	172

Residential, garage Residential, Living Area (Not Finished Basement) Residential, Un-Finished basements		705 2922 1165	
Roofing Material		Number of Bathrooms	4
Number of Bedrooms	5	Number of Stories	2
Number of Living Units	1	Total Living Area	2922
Sewer Connection Fee	20		