

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213431
Address: 420 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Shawn Hoffman	Failed	Friday, June 24, 2022

Corrective Action Required:

1	Misc	- post address - fire block expansion joint in block wall - label all electrical panels - repair fire rated wall top of stairs [b] door handle
---	------	---

Comments: