

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220431  
Address: 420 SW LONGVIEW BLVD, Unit:116, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Shawn Hoffman	Failed	Friday, June 24, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- No TCO until shell is approved</li><li>- Post address</li><li>- obtain an Irrigation permit and submit a back flow certification</li></ul>
	A	<ul style="list-style-type: none"><li>- bathroom sink max 34" ADA compliant</li><li>- Provide handy-cap mirror</li><li>- Label panel</li><li>- Missing outlet covers</li><li>- Complete lighting</li><li>- Label electrical panel</li></ul>

**Comments:**