

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213431  
Address: 420 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Storm Sewer Construction Inspection</b>	Ronald Paynter	Partial	Friday, June 24, 2022

Informational:		
1	Misc	Temp Stop installed boxes 105 and 106 after connecting to existing 15" storm pipe. They also poured collars and were pouring inverts this afternoon.
Informational:		
2	Misc	Temp Stop installed 6 roof drains and connected them to the storm box. Informed them to get the correct storm lid (missing the stamping info). RP 11-11-21
Corrective Action Required:		
3	Misc	Storm lid near road inlet needs replaced with a lid that reads "STORM". Also need to have lifting cables removed and grouted on top of parking lot inlet. 6/24/22 ES

**Comments:**