

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20216411  
Address: 710 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 2</b>	Eric Sharp	Partial	Friday, June 24, 2022

Informational:  
1 Misc Pulled 2nd set of samples at 9:45-10am. 6/22/22 ES  
2nd Set of samples had a failure. Will need to retest. 6/24/22 ES

**Comments:**