



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20100205
Address: 350 SW BLUE PKWY, LEES SUMMIT, MO 64063
Inspected On: Friday, February 18, 2011
Inspected By: Mark Harding
Expiration Date: 3/4/2011 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Temporary C of O	Friday, February 18, 2011

Corrective Action Required:

1 MISC SLOPE OF RAMPS MAY NOT EXCEED 1:12 FOR ADA/ANSI COMPLIANCE. SEE SOUTH ENTRANCE.

Corrective Action Required:

2 MISC STEPS/STAIRS AT COMMERCIAL BUILDINGS MUST HAVE COMPLIANT HANDRAILS -- ONE EACH SIDE OF STAIR. SEE NORTH ENTRANCE.
TEMP HANDRAILS IN PLACE

Corrective Action Required:

3 MISC PER NEC 600.3 EACH ELEMENT OF LIGHTED SIGNS MOUNTED DIRECTLY ON BUILDING SURFACE MUST BEAR LISTING LABEL VISIBLE FOR INSPECTION.
REAR SIGN OK

Corrective Action Required:

4 MISC EXTERIOR BUILDING FINISH MUST BE COMPLETED. SEE

DRIVE-THROUGH AND ROOFTOP TOWER AT SOUTH
ENTRANCE.

Corrective Action Required:

8

MISC

APPROVED FOR 14DAY TCO

SEE FIRE DEPART. FOR APPROVAL
(FIRE DEPART- OK FOR TCO)

Comments: