



Automotive Technology, Inc.

544 Mae Court, Fenton, MO 63026
636-343-8101 • Fax: 636-343-5597 • Toll Free: 1-800-875-8101
www.automotivetechology.com
E-mail: doug@automotivetechology.com



27 June 2022

Permit# PRCOM20222560
To: Jim Eden
Subject: Plan Review Responses

Thank you for the review of our permit application. Below are the responses to each notation.

1. Allstate Fire, Todd Thompson has addressed this comment in separate email
2. Portable Fire extinguishers-A portable fire extinguisher will be installed on the outside of the mixing room.
 Paint booths and Mixing room are covered by dry chemical fire suppression system.
3. Allstate Fire, Todd Thompson has addressed this comment in separate email
4. Exemption 2 is applicable. Building is a metal building (non-combustible material) allowing the paint booth to be closer than 3'. All electrical components (i.e. lights) are explosion proof and accessible from the inside for maintenance. No maintenance items on the outside of the booth walls.

Please let me know if you have any additional comments/questions.

Doug Slattery
President