

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213319  
Address: 1418 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Monday, June 27, 2022

Corrective Action Required:

1	Misc	-RESOLVE OUTSTANDING INSPECTION FEES -LABEL ALL BREAKER LOCATIONS AT SUB PANEL -SHEAR OFF SET SCREW ANTI SIPHON DEVICE ON SPIGOT MAIN WATER LINE BASEMENT -REMOVE DUST COVERS FROM SMOKES -UNCOVER MANHOLE AT FRONT OF LOT AS SHOWN ON PLOT PLANS
---	------	---

**Comments:**