## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## Temporary Certificate of Occupancy

Permit #: PRRES20213690

Address: 1217 NE GOSHEN DR, LEES SUMMIT, MO 64064

Inspected On: Monday, June 27, 2022

**Inspected By:** Khanh Nguyen

Expiration Date: 7/27/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Inspection: Outcome: Date:

Occupancy Inspection - Khanh Nguyen Temporary C of O Monday, June 27,

Codes Residential 2022

Corrective Action Required:

1 Misc -Provide landscaping at rear of lot per plot plan

-Water meter buried \*\*The meter is too far below grade. Either raise

the meter so that the meter-to-lid distance is 14"-18" or get

approval from the water meter department

-Final grade, sod, downspout and sump pump extension