



## **FIRE DEPARTMENT**

**Prevention Division  
(816)969-1300**

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20216411	Date:	June 27, 2022
Project Title:	CALIBER COLLISION	Applicant:	
Location:			
710 SE BLUE PKWY, LEES SUMMIT, MO 64063		FALCON FIRE PROTECTION INC	
Type of Work:		1239 A CLAY ST	
Occupancy Group:	S-1	NORTH KANSAS CITY, MO 64116	
Description:	NEW BUILDING FOR COLLISION		
REPAIR			
Construction Type:	Type IIB (Unprotected)	<NO CONTACT NAME AVAILABLE>	
Map Page:		<NO CONTACT INFORMATION AVAILABLE>	

Primary: (816) 401-1833

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule a hydrostatic and flow test.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**