

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213583

Address: 3825 SW WALSH DR, LEES SUMMIT, MO 640823823 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Diana Johnson	Passed	Thursday, June 23, 2022

Informational:

1 Misc

On 5.11.2022 I performed a sidewalk inspection and pass the sub-grade to pour concrete

On 6.23.2022 the sidewalk appears to be compliant

Comments: