CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20213583Address:3825 SW WALSH DR, LEES SUMMIT, MO 640823823 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, June 27, 2022
Corrective Action Required: 2 Misc	Maintain erosion control until sod is in place.		
	 3823 Final grade (provide as graded plot plan) -sod -splash blocks and sump pump discharge to extend 36" from foundation -check water meter at time of final grade and sod -secure ac whip within 12" of disconnect -seal all exterior penetrations -garage entry door must be self closing and latching -outlets in garage must comply with code section E3901.9 of the irc 		
	3825		
	Final grade (provide as g -sod -splash blocks and sump -check water meter at ti -garage entry door must -outlets in garage must	pump discharge to e me of final grade and be self closing and l	atching

Comments: