

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213585

Address: 3822 SW WALSH DR, LEES SUMMIT, MO 640823824 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Monday, June 27, 2022

Corrective Action Required:

1	Misc	-Sheetrock Ufer ground location and install sheetrock mud ring and an approved electrical cover plate.-PROVIDE APPROVED ELECTRICAL COVER PLATE -resolve all outstanding fees -final grade and sod' -submit as graded plot plan for review and approval -splash blocks
---	------	---

Comments: