

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213323

Address: 3813 SW WALSH DR, LEES SUMMIT, MO 64082 3811 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|------------------------|
| Occupancy Inspection - Codes Residential | Patrick Schonfeldt | Failed | Tuesday, June 28, 2022 |

Corrective Action Required:

1 Misc

CORRECTIONS FOR BOTH UNIT 3811 AND 3813

-resolve all outstanding inspection fees

-Provide permanent address labels at meter can and disconnect

-support deck beams

-splash blocks all downspouts and sump pump locations, min 36" discharge from foundation

UNIT 3811 OK FOR TCO, TCO EXPIRES 7/19/22**

UNIT 3813: NO OCCUPANCY INSPECTION PERFORMED, CORRECTING SEWER AT TIME OF INSPECTION, PROVIDE ADDRESS

Comments: