



June 27, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field issue of modified truss - C3 - for Lot #92 Reserve at Stoney Creek –4395 SW Amethyst Dr. Lee's Summit, MO 64082 – Permit # PRRES20212841

Findings:

- Gable end has been modified to be field framed with 2x4's @ 16" O.C.
- Truss C3 has been cut and is only supporting self-weight.

Recommended Modifications:

- Install a sistered 2 x 4 stud to existing 2x4 gable truss studs at 4' O.C. on exterior gable wall.
- Attach existing truss webs to sistered 2 x 4 studs with SDS structural screws or 10D nails @12" O.C.

Sincerely,

A handwritten signature in blue ink, appearing to read "Bradley Huxol", written over a light blue horizontal line.

Bradley Huxol, PE

