

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210347
Address: 1221 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Tuesday, June 28, 2022

Corrective Action Required:

1	Misc	-As-graded plot plan is required prior to sodding
		-Bottom of rear siding shall have min 6" clearance to soil grade
		-Final grade, sod, downspout and sump pump extensions
		-The sewer tracer wire and port are not installed and available at grade level
		-Provide gfci protection for dish washer per NEC 210.8(D). Receptacles not tripping

Comments: