

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214081

Address: 2009 SW OSAGE DR, LEES SUMMIT, MO 640822011 SW OSAGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, June 28, 2022

Corrective Action Required:

1	Misc	- REVISE PERMIT FOR CORRECT ADDRESS OF DUPLEX FOR BASEMENT FINISH ON 2009 AND NOT 2011 - FIREBLOCK VERTICAL TO HORIZONTAL AT FURRED SOFFIT ENDS
---	------	--

**Comments:**