

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215300  
Address: 500 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Robb Popp	Failed	Wednesday, June 29, 2022

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	BUILDING FOOTING PER PLAN OK TO POUR, COVER POUR TO PROTECT AGAINST WEATHER. UFER LOCATED NORTH END OF BLDG FOOTING TRASH ENCLOSURE
---	----------------------------------	---

Corrective Action Required:

2	Misc	Provide pier per approved structural drawings at monument sign
---	------	--

**Comments:**