

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20214936

Address: 1745 SE HAMBLER RD, LEES SUMMIT, MO 640821800 SE RANSON RD, LEES SUMMIT, MO  
640821001 SE BAILEY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                      | Inspector: | Outcome: | Date:                       |
|----------------------------------|------------|----------|-----------------------------|
| <b>Sanitary Sewer - Air Test</b> | Tom Taylor | Passed   | Wednesday, June 29,<br>2022 |

Informational:

1 Misc

On Monday, 6-20-2022, Site Rite Construction performed Vacuum testing and pressure testing on Sanitary sewers for this project. All testing passed except Man Hole #5. Man Hole did not hold required vacuum. Contractor will review and correct vacuum issue.

**Comments:**