

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20214936

Address: 1745 SE HAMBLER RD, LEES SUMMIT, MO 640821800 SE RANSON RD, LEES SUMMIT, MO
640821001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Tom Taylor	Passed	Tuesday, June 21, 2022

Informational:

1 Misc

On Monday and Tuesday, 6-21-2022 the contractor completed and passed air an vacuum testing for the 15" sewer system.

On Tuesday 6-21-2022 Contractor completed and passed all vacuums test for all man holes

Informational:

2 Misc

31 day date for sewer to be tested/video by City of Lee's Summits Water Service will by JULY 7, 2022

Comments: