

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213681  
Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Tuesday, June 28, 2022

Corrective Action Required:

1 FIRST FLOOR

Corrective Action Required:

2 SECOND FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS

AREA "B"

230 -235 OK

241-overbored stud at party wall , fireblock dead space at bathroo, seal top plate penetration, protect dryer duct 24-hvac4-protect dryer duct

243-

244-Protect dryer duct

245-complete hvac

247-protect dryer/structural strap

246-add stud at over bored stud in corridor outside of unit

249-complete rated layer at bath

248-complete pex at shower, Bocca plates at pex, protect dryer duct

Corrective Action Required:

3 THIRD FLOOR

THE FOLLOWING AREAS ARE APPROVED:

AREA "A" UNITS AND CORRIDORS  
AREA "B" UNITS AND CORRIDORS

Corrective Action Required:

4            STAIR TOWER 1      STAIR TOWER "A"  
   -3RD FLOOR OK

Corrective Action Required:

5            STAIR TOWER 2      STAIR TOWER "B"  
   -3RD FLOOR OK

Corrective Action Required:

6            STAIR TOWER 3      STAIR TOWER "C"  
   -3RD FLOOR OK

**Comments:**