

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215763
Address: 3116 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, June 29, 2022

Corrective Action Required:

1	Misc	No further inspections until gravel filter is in compliance
		-fire block laundry /garage wall to furr down
		-stud shoe for hole drill to close to edge for SE cable
		-cspf basement windows to plans and design

Comments: